

PERMIT NUMBER: 05-136RR

FEE:

TOWN OF ACTON - BOARD OF HEALTH

DATE: 10/28/2005

THIS IS TO CERTIFY THAT MIKE MAIMONE

of 253A SCHOOL STREET, ACTON,, MA

**is hereby granted permission to have a licensed installer
install a SEWERAGE DISPOSAL SYSTEM on the premises at:
253A SCHOOL ST**

In accordance with an application received by the Board of Health on 10/17/2005 and the approved plans:

By Steven Calichman, RS dated 10/17/05.

Approval is subject to limiting the rate of sewage disposal to not more than 440 gallons per day and pumping the septic tank every two years.

This permit expires on 10/28/2007. Any variation during installation of the sewerage disposal system from the plans approved by the Board of Health should be reported to the design engineer and the Board of Health or their agent for their review and comment prior to continuing construction of the sewerage disposal system.


AGENT OF THE BOARD OF HEALTH

Violation of any of the requirements or conditions will cause immediate revocation of this permit.

GENERAL REQUIREMENTS AND CONDITIONS

This installation requires compliance with Acton Board of Health regulations #11-2, #11-3, #11-3.1, 11-3.2, #11-11, #11-11.1, #11-11.2 and #11-11.3. In summary these regulations require that the owner of the land is responsible for all work being done in compliance with the approved applications and plans. All work performed must be by a Disposal Works Installer who is licensed by the Town of Acton and all work must be inspected and approved by the Board of Health or its agent.

***In addition the Board of Health requires inspection of all construction by a Registered Professional Engineer and requires that such engineer certify in writing that all work has been completed in accordance with the terms of the permit and the approved plans.**

APPROVED
OCT 28 2005
ACTON BOARD
OF HEALTH



Town of Acton, Massachusetts

Certificate of Compliance

This is to Certify, that the On-site Sewage Disposal System installed ☐ or repaired/replaced ☒, which was completed on 4/19/06 by ABC CESSPOOL CO., INC. for Mike Maimone at 253 A School St. has been constructed in accordance with the provisions of Title 5 and the Disposal System Construction Permit No. DS436RR dated 10/28/05

Use of this system is conditioned on compliance with the provisions set forth below:

The issuance of this certificate shall not be construed as a guarantee that the system will function as designed.

Signatures:

DATE 5/1/06

DATE 5/1/06

DATE 5/1/06

DATE 5/3/06

DATE 5/3/06

DESIGNER [Signature]

INSTALLER [Signature]

REGISTERED
SANITARIAN Steven Calichman

ELECTRICAL
INSPECTOR NA

APPROVING
AUTHORITY [Signature]

ABC CESSPOOL CO. INC.
ABC CESSPOOL CO., INC.